



PARASQUARE 5

3/4" x 3/4" x 3/8" cell size

PHOTOMETRIC TEST DATA

Catalog Number: P5-24-1
 Building Acoustics & Lighting Laboratories, Inc.
 Certified Test Report: 8641.0 1/22/96
 Commercially available **2x4 troffer**: Refl=92%
3-32 Watt T8 Lamps: F32T8/735/RS
 Rated Lumens: 2850
 Watts: 87

CANDLEPOWER DISTRIBUTION

VERT ANG	HORIZONTAL ANGLE					ZONAL LUMENS
	0	22.5	45	67.5	90	
0	2641.	2641.	2641.	2641.	2641.	
5	2660.	2675.	2685.	2688.	2676.	255.7
10	2663.	2681.	2702.	2737.	2743.	
15	2618.	2652.	2707.	2719.	2714.	761.4
20	2538.	2575.	2644.	2748.	2756.	
25	2383.	2427.	2554.	2644.	2663.	1174.3
30	2175.	2248.	2400.	2507.	2564.	
35	2035.	2130.	2315.	2470.	2517.	1443.4
40	1832.	1980.	2204.	2351.	2413.	
45	1711.	1916.	2164.	2361.	2395.	1644.5
50	1445.	1664.	1890.	2052.	2104.	
55	1181.	1350.	1508.	1638.	1726.	1334.4
60	499.	699.	787.	782.	688.	
65	13.	53.	157.	13.	11.	58.3
70	6.	6.	8.	8.	8.	
75	6.	6.	6.	6.	6.	6.3
80	4.	4.	4.	4.	4.	
85	1.	1.	1.	1.	1.	1.1
90	0.	0.	0.	0.	0.	

TESTED IN ACCORDANCE WITH CURRENT IES PRODEDURES.

IES SPACING CRITERIA:
 END: 1.2
 DIAGONAL: 1.4
 CROSS: 1.5

VISUAL COMFORT PROBABILITY 100. FC WORK PLANE ILLUMINATION

REFLECTANCES:
 WALL= .50
 CEILING CAVITY= .80
 FLOOR CAVITY= .20

LUMINAIRES LENGTHWISE LUMINAIRES CROSSWISE

ROOM DIM	MOUNTING HEIGHT										
	W	L	8.5	10	13	16	8.5	10	13	16	
20	20	87	78	70	76	84	74	64	70		
20	30	89	82	76	74	87	79	72	69		
20	40	91	85	80	77	89	82	77	72		
20	60	92	87	83	80	91	84	80	76		
30	20	90	83	73	73	88	80	68	69		
30	30	92	86	79	71	91	84	75	67		
30	40	93	88	82	76	92	86	79	73		
30	60	94	90	85	79	93	88	82	76		
30	80	95	91	87	81	94	89	84	79		
40	20	92	87	77	74	91	84	73	71		
40	30	94	89	82	73	93	87	79	70		
40	40	95	91	86	77	94	89	83	75		
40	60	95	92	88	80	95	90	85	78		
40	80	96	93	89	83	95	91	87	81		
40	100	96	94	90	84	96	92	89	82		
60	30	95	91	85	76	94	89	82	74		
60	40	96	92	88	80	95	91	86	78		
60	60	96	93	89	83	96	92	88	81		
60	80	97	94	91	85	96	93	89	83		
60	100	97	95	92	87	96	94	90	85		
100	40	97	94	91	85	96	93	89	83		
100	60	97	95	92	87	97	94	90	85		
100	80	97	96	93	88	97	95	92	87		
100	100	98	96	94	89	97	95	93	88		

LUMEN SUMMARY

ZONE	LUMENS	%LAMP	%FIXT	ZONE	LUMENS	%LAMP	%FIXT
0- 30	2191.	25.6	32.8	90-120	0.	.0	.0
0- 40	3635.	42.5	54.4	90-130	0.	.0	.0
0- 60	6614.	77.4	99.0	90-150	0.	.0	.0
0- 90	6680.	78.1	100.0	90-180	0.	.0	.0
TOTAL LUMINAIRE				0-180	6680.	78.1	100.0

LUMINANCES-CD/SQ-M HORIZONTAL ANGLE

VERT ANGLE	0		45		90		MAX/AV RATIO
	AVG	MAX	AVG	MAX	AVG	MAX	
45	3904.	7279	1.9	4938.	5465.	8996	1.6
55	3322.	6313	1.9	4242.	4855.	7894	1.6
65	50.	856	17.2	599.	42.	904	21.5
75	37.	275	7.4	37.	37.	231	6.2
85	19.	476	25.7	19.	19.	275	14.9

ZONAL CAVITY COEFFICIENTS OF UTILIZATION

EFFECTIVE FLOOR CAVITY REFLECTANCE=.20

CEILING WALL RCR	.80		.70		.50		.30		.10		.00							
	.70	.50	.30	.10	.70	.50	.30	.10	.50	.30	.10	.00						
0	.93	.93	.93	.93	.91	.91	.91	.91	.87	.87	.87	.83	.83	.83	.80	.80	.80	.78
1	.87	.85	.82	.80	.85	.83	.81	.79	.80	.78	.76	.77	.75	.74	.74	.73	.72	.70
2	.82	.77	.73	.70	.80	.76	.72	.69	.73	.70	.67	.71	.68	.66	.68	.66	.65	.63
3	.76	.70	.65	.61	.74	.69	.64	.60	.66	.63	.59	.64	.61	.58	.63	.60	.57	.56
4	.70	.63	.57	.53	.69	.62	.57	.53	.60	.56	.52	.58	.54	.51	.57	.53	.51	.49
5	.65	.56	.51	.46	.63	.56	.50	.46	.54	.49	.45	.53	.48	.45	.51	.48	.45	.43
6	.60	.51	.45	.40	.58	.50	.44	.40	.49	.44	.40	.47	.43	.39	.46	.42	.39	.38
7	.55	.45	.39	.35	.54	.45	.39	.35	.44	.38	.34	.43	.38	.34	.42	.37	.34	.33
8	.50	.40	.34	.30	.49	.40	.34	.30	.39	.34	.30	.38	.33	.30	.37	.33	.29	.28
9	.46	.36	.30	.26	.45	.36	.30	.26	.35	.29	.25	.34	.29	.25	.33	.28	.25	.24
10	.43	.33	.27	.23	.42	.32	.26	.22	.31	.26	.22	.31	.26	.22	.30	.25	.22	.21





PHOTOMETRIC TEST DATA

Catalog Number:
Building Acoustics & Lighting Laboratories, Inc.
Certified Test Report:
Commercially available **2x4 troffer**: Refl=92%
3-32 Watt T8 Lamps: F32T8/735/RS
Rated Lumens: 2850
Watts: 87

TESTED IN ACCORDANCE WITH CURRENT
IES PRODEDURES.

IES SPACING CRITERIA:
END:
DIAGONAL:
CROSS:

